

Memo No:- 988

Date:- 07/09/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : SNP/02182/9/2026 / Private	Sample Details	Date & Time
Sender : Suresh Kumar Sharma	Collected By	Principal, New...
Location : , New Tagore Sr. Sec. School	Collection Date	31/08/2026 at 12:38
Sample Description : Drinking Water	Received at lab	02/09/2026 at 13:17
Latitude / Longitude : 77.122120 / 28.961464	Analysis Start Date	02/09/2026
	Analysis End Date	03/09/2026
	Sample Quantity	2 ltrs

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.15	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	5.0	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	1236	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO ₃	590	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium (as Ca)	124.25	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium (as Mg)	63.18	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	480	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride (as Cl)	173.95	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So ₄	105	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
12	Fluoride (as F)	0.70	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
13	Iron (as Fe)	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate (as NO ₃)	1.4	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
15	pH @ 25°C	6.69	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED SONIPAT Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

SONIA ,CHEMIST
DISTRICT WATER TESTING LABORATORY,SONIPAT
email:-chemist.sonepat@phedharyana.gov.in